
REVISED - CITY OF NEW ORLEANS 06/23/2015



FOUNDATION PLAN


SCALE: 3/32" = 1'-0"


STRUCTURAL ENGINEER

WALTER F. ZEHNER

4702 TOULOUSE ST
NEW ORLEANS, LOUISIANA 70119
(504) 488-1442

E-MAIL:WALTERZEHNER@MSN.COM





PROJECT#: 0827

PHASE: DD


DRAFTER: VICTOR RINCON, BE

CHECKER: HANK SMITH

SCALE: AS NOTED

ISSUED: 06/17/2015


SHEET#





## STRUCTURAL ENGINEER

WALTER F. ZEHNER 4702 TOULOUSE ST NEW ORLEANS, LOUISIANA 70119 (504) 488-1442 E-MAIL:WALTERZEHNER@MSN.COM



ARCHITECTS PLLC 189 Maple Ridge Drive Metairie, LA 700 (504)885-4477 :: Fax(504)885-4 central@hbsaii.com :: www.hbsaii.c


SINCE 1961

 $\mathcal{C}$ 

THESE PLANS AND SPECIFICATIONS
BEEN PREPARED BY ME OR UNDE
CLOSE PERSONAL SUPERVISION AN
THE BEST OF MY KNOWLEDGE
BELIEF THEY COMPLY WITH ALL
STATE AND FEDERAL REQUIREMENTS,
I AM NOT PROVIDING CONTF
ADMINISTRATION.

CERTIFIED CORRECT

THIS DRAWING IS CONFIDENTIAL AN NOT BE LOANED, REPRODUCED, CC EITHER WHOLLY OR IN PART, OR PUBLIC IN ANY MANNER WITHOUT WRITTEN CONSENT OF HBS ARCHITECTS, A PROFESSIONAL LALL RIGHTS OF DESIGN OR INVENARE RESERVED AND WILL REMAIN SOLE PROPERTY OF HBS ARCHITECTS A PROFESSIONAL L.L.C.




PROJECT#: **0827** 

PHASE: DD


RAFTER: VICTOR RINCON, BD CHECKER: HANK SMITH


SCALE: AS NOTED

ISSUED: 06/17/2015



S2.1 SCALE: 3/4'' = 1'-0''






SECTION S2.1 SCALE: 3/4'' = 1'-0''

## FOUNDATION NOTES:

- 1. PILING SHALL BE TREATED TIMBER PILES OF SOUTHERN YELLOW PINE OR DOUGLAS FIR CONFIRMING TO A.S.T.M. D-25 WITH A MINIMUM TIP DIAMETER OF 7" AND A NATURAL TAPER TO THE BUTT. PILES SHALL BE DRIVEN TO A REFUSAL OF 25 BLOWS/FOOT WITH A VULCAN #1 OR EQUIVALENT HAMMER TO ABOUT 41 FEET BELOW GRADE. DESIGN LOAD IS 25 TONS PER PILE AS PER PILE LOAD TEST BY STRATUM ENGINEERING, LLC, DATEDJULY 27, 2012.
- 2. ALL CONCRETE SHALL BE STANDARD WEIGHT AND SHALL TEST AT 5000 PSI AT 28 DAYS. IT SHALL BE IN ACCORDANCE WITH THE LATEST EDITIONS OF ACI 301 AND 318.
- 3. REINFORCING STEEL SHALL BE NEW BILLET ASTM A-615 GRADE 60. DETAIL REINFORCING AND PROVIDE ACCESSORIES IN ACCORDANCE WITH THE LATEST ACI MANUAL OF STANDARD PRACTICE. PROVIDE 30 DIAMETER LAP SPLICES AT ALL DISCONTINUOUS TOP BARS. PROVIDE CORNER BARS SAME SIZE AND NUMBER AS OUTSIDE BEAM BARS WITH 30 DIAMETER LAP EACH WAY.
- 4. REINFORCING CLEARANCES ARE REQUIRED AS FOLLOWS. SLAB: 1" CLEAR BOTTOM AND 3/4" CLEAR TOP
- BEAMS: 1.5" CLEAR IF FORMED AND 3" CLEAR IF EARTH FORMED PILE CAPS (FOOTINGS): 3 " CLEAR TOP & SIDES AND 6" CLEAR BOTTOM
- 5. FOUNDATION HAS BEEN DESIGNED IN ACCORDANCE WITH 2012 INTERNATIONAL BUILDING CODE AND FOR A BASIC WIND SPEED (3 SECOND GUST) OF 130 MPH AND EXPOSURE B IN ACCORDANCE WITH THE PROVISIONS OF A.S.C.E.-7.

STRUCTURAL ENGINEER

WALTER F. ZEHNER 4702 TOULOUSE ST NEW ORLEANS, LOUISIANA 70119 (504) 488-1442 E-MAIL:WALTERZEHNER@MSN.COM



PLLC 189 Maple Ridge Drive Metairie, LA 700 (504)885-4477 :: Fax(504)885-4 central@hbsaii.com :: www.hbsaii.c


SINCE 1961

THESE PLANS AND SPECIFICATIONS BEEN PREPARED BY ME OR UNDE CLOSE PERSONAL SUPERVISION AN BELIEF THEY COMPLY WITH ALL STATE AND FEDERAL REQUIREMENTS, I AM NOT PROVIDING CONTE

CERTIFIED CORRECT

THIS DRAWING IS CONFIDENTIAL AN NOT BE LOANED, REPRODUCED, CC EITHER WHOLLY OR IN PART, OR PUBLIC IN ANY MANNER WITHOUT WRITTEN CONSENT OF HBS ARCHITECTS, A PROFESSIONAL LALL RIGHTS OF DESIGN OR INVENARE RESERVED AND WILL REMAIN SOLE PROPERTY OF HBS ARCHITECTS A PROFESSIONAL L.L.C.

REVISION HISTORY



PILE CAP DETAILS

PROJECT#: **0827** 

PHASE: DD RAFTER: VICTOR RINCON, BD CHECKER: HANK SMITH

> SCALE: AS NOTED ISSUED: 06/17/2015

SHEET#

